Town of Wilmington Wastewater Facilities 20 Year Evaluation

Selectboard Presentation
April 3, 2013

20 Year Evaluation

- ➤ Completed in 2012
- ➤ Typically required by Discharge Permit
- Recommendations and implementation plan for sewer collection system, pump stations and wastewater treatment facility



Scope of Evaluation

- ➤ Summarize and review current operating conditions
- Document recent inspections of sewer collection system
- Assess the pump stations and wastewater treatment facility
- ➤ Develop a recommended plan


Wastewater Facilities

- Sewer Collection
 System
- Pump Stations
- Wastewater Treatment Facility



Sewer Collection System

- As required by the State, the Town prepared "Operation, Management and Emergency Response Plan" in January 2009 and amended in June 2010
 - > Sewer system mapping
 - > Stream crossing inspections
 - ➤ Manhole inspections
 - ➤ Pipeline cleaning and TV inspection



Wastewater Pump Stations and

Ejector Stations

➤ PS #1: West Main Street

➤ PS #2: WWTF Influent

> PS #3: Route 9 West

> PS #4: Woffenden Road

> EJ #1: East Main Street

➤ EJ #2: Bowling Alley

> EJ #3: Alpine Rental



Wastewater Treatment Facility Background


- Original plant constructed in 1960's
- Upgraded to secondary treatment in 1987



Flow and Effluent Quality

- > Flows
 - ➤ Permitted: 0.135 mgd
 - > 2011 Actual: 0.0859 mgd (64%)
- > Effluent Quality
 - > Consistent compliance





Assessment Example for RBC's

	Ranking of Existing Condition					Projected	
	Poor		Fair		Good	Remaining Life (years)	
Item	1	2	3	4	5	(721-3)	Notes
Influent flow splitter			Х			20	Installed in 1987
RBC unit #1		Х				< 5	Installed in 1987
RBC unit #2		X				< 5	Installed in 1987
Concrete tanks			Х			20+	Installed in 1987
Grating			Х			< 10	
Fiberglass enclosures			Х			< 10	Installed in 1987

Influent Pump Station Major Deficiencies

- ➤ Pump #1
- > Pump control system



Headworks Major Deficiencies

- > Concrete structure
- **→** Gates
- > Lack of handrails



Clarigester Major Deficiencies

- > Handrails
- > Weirs
- > Skimmer and rake arms
- > Concrete structure
- > Scum box



RBC's Major Deficiencies

- RBC units
- Fiberglass covers



Control Building Major Deficiencies

- Roof
- Exterior
- Heating/ventilation
- Motor control center



Office Building Major Deficiencies

- > Lab furnishings
- > Exterior
- > Roof
- > Heating/ventilation
- Motor control center



Evaluation of Primary Treatment Alternatives

- ➤ No. 1: Upgrade Existing Clarigester Tank
- No. 2: Primary Clarifiers– Circular
- No. 3: Primary ClarifiersRectangular
- ➤ No. 4: Salsnes Filter



Technical and Economic Evaluation

- Develop preliminary design criteria
- Advantages/
 Disadvantages
- Estimated Construction Costs:
 - > \$285,000 to \$580,000



Capital Planning

- Sewer Collection
 - Prioritize manhole and sewerline rehab
- Pump and Ejector Stations
 - > PS #1: West Main Street
 - > PS #4: Woffenden Road
 - > EJ #3: Alpine Rentals
- Wastewater Treatment Facility
 - Small equipment replacement; influent pump, valves, mixers



Future Planning

- Pump Stations
 - ➤ Ejector Station #1: Mobile Station
- ➤ Wastewater Treatment Facility
 - ➤ Influent Pump Station controls
 - > Clarigester and primary treatment upgrades
 - ➤ RBC's
 - ➤ Control Building
 - ➤ Office Building

Next Steps

- ➤ January 2013: A priority list application was submitted
- ➤ 2014: Begin preliminary engineering study for wastewater treatment facility upgrades